Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 1 of 65 page



TEST REPORT IEC 60947-5-1 Part 5: Control circuit devices and switching elements Electromechanical control circuit devices

Report Number:	TCT-TR01-221125-4				
Date of issue:	2022-11-25				
Total number of pages	65 pages				
Name of Testing Laboratory preparing the Report:	Tyger CT Corp. / #818, BUILDING B, DONGTAN KUMGANG PENTERIUM IX TOWER 27, DONGTANCHEOMDANSANEOP 1- RO HWASEONG-SI Republic of Korea				
Applicant's name:	KG Auto Co. Ltd.				
Address:	45, Sojeongsandan 4-ro, Sojeong-myeon, Sejong-si,				
	Republic of Korea				
Test specification:					
Standard:	EN 60947-5-1:2017 + AC:2020-05				
Test procedure:	CE(LVD)				
Non-standard test method	N/A				
Test Report Form No	IEC60947_5_1H				
Test Report Form(s) Originator :	DEKRA Certification B.V.				
Master TRF:	Dated 2020-12-18				
Copyright © 2020 IEC System of Con Equipment and Components (IECEE	Copyright $^{\odot}$ 2020 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.				
This publication may be reproduced in whole or copyright owner and source of the material. IEC from the reader's interpretation of the reproduce	in part for non-commercial purposes as long as the IECEE is acknowledged as EE takes no responsibility for and will not assume liability for damages resulting d material due to its placement and context.				

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved IECEE Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing NCB. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.



Test it	tem description:	Hoist S	Switch	
Trade Mark:				
Manut	facturer	KG Au	to Co. I td	
Mode			vz series	
Dating				
Rating	ys	AC-12	, AC-13 250Va.C 6A	
Respo	onsible Testing Laboratory (as a	pplicat	ole), testing procedure	and testing location(s):
	Testing Laboratory:		Tyger CT Corp.	
Testir	ng location/ address	:	#818, Building B, Dong Tower, 27, Dongtanch si, Gyeonggi-do, Korea	gtan Kumgang Penterium IX eomdansaneop 1-ro, Hwaseong- a
Teste	d by (name, function, signature)	:	SeonGwang Kim	Squang
Appro	oved by (name, function, signatu	ıre):	SungMarn Park	Vmr
	Testing procedure: CTF Stage 1:		N/A	
Testing location/ address:				
Teste	d by (name, function, signature)	:		
Appro	oved by (name, function, signatu	ıre):		
	Testing procedure: CTF Stage 2:	:	N/A	
Testir	ng location/ address	:		
Teste	d by (name + signature)	:		
Witne	ssed by (name, function, signat	ure).:		
Appro	oved by (name, function, signatu	ire):		
	Testing procedure: CTF Stage 3:		N/A	
Testing procedure: CTE Stage 4:				
Testing location/ address:				
Teste	Tested by (name, function, signature)			
Witne	ssed by (name, function, signat	ure).:		
Appro	oved by (name, function, signatu	, ire):		
Super	vised by (name. function. signal	, ture) :		



List of Attachments (including a total number of	List of Attachments (including a total number of pages in each attachment):			
Summary of testing: This report may consist of more than one report and reports:	d is only valid with additional or previous issued			
Report Ref. No : 50036671001				
Tests performed (name of test and test	Testing location:			
Related all clauses	Tyger CT Corp. / #818, BUILDING B, DONGTAN KUMGANG PENTERIUM IX TOWER 27, DONGTANCHEOMDANSANEOP 1- RO HWASEONG-SI Republic of Korea			
Summary of compliance with National Differenc	es (List of countries addressed):			
\square The product fulfils the requirements of <u>EN 60947-5-1 : 2017</u> (insert standard number and edition and delete the text in parenthesis, leave it blank or delete the whole sentence, if not applicable)				
Statement concerning the uncertainty of the me	asurement systems used for the tests			
(may be required by the product standard or client)				
Internal procedure used for type testing through which traceability of the measuring uncertainty has been established:				
Procedure number, issue date and title:				
Calculations leading to the reported values are on file with the NCB and testing laboratory that conducted the testing.				
Statement not required by the standard used for type testing				
(Note: When IEC or ISO standard requires a statement concerni should be reported above. The informative text in parenthesis sh	ng the uncertainty of the measurement systems used for tests, this nould be delete in both cases after selecting the applicable option)			



Copy of marking plate:

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.



General product information and other remarks :

Models covered by this test report.

Type designation : KG-Lxyz series

x stands for : number of push buttons

(02 : 2 buttons, 04 : 4 buttons)

y stands for : Button composition

(A: 1a – 1a (1 stage contact block),
T: 2a – 2a (1 stage contact block),
AA : for double As (A used twice),

TT : for double Ts (T used twice))

z stands for : Option

(Blank or K : Long-tyge cable grand, M : magnet attached)

Test samples submitted for tests KG-L04TT

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 5 of 65 page



Test item particulars	
Classification of installation and use	Hoist switch for PENDANT CONTROLLER
Supply Connection	N/A
Kind of control circuit device:	\boxtimes manual control switches, e.g. push-buttons, rotary switches, foot switches, etc.
	electromagnetically operated control switches, either time delayed or instantaneous, e.g. contactor relays
	pilot switches, e.g. pressure switches, temperature sensitive switches (thermostats)
	\boxtimes position switches
	associated control equipment, e.g. indicator lights, etc.
Kind of switching elements:	auxiliary contacts of a switching device (e.g. contactor, circuit-breaker, etc) which are not dedicated exclusively for use with the coil of that device
	interlocking contacts of enclosure doors
	control circuit contacts of rotary switches
	control circuit contacts of overload relays
Number of poles	2 to 4
Kind of current:	ig lpha ac and/or $ig $ dc
Interrupting medium	🛛 air, 🗌 oil, 🗌 gas, 🗌 vacuum, 🗋
Operating conditions:	
Method of operations:	🖂 manual
	electromagnetic
	pneumatic
	electro-pneumatic
Method of control	automatic
	⊠ non-automatic
	semi-automatic

11	CONSULTING & TESTING	-	1	-
	YGER	U	57	

Rated and limiting values for switching elements:	
Voltages:	
- rated operational voltage Ue (V)	250V
- rated insulation voltage Ui (V)	300V
- rated impulse withstand voltage Uimp (kV)	4kV
Currents:	
- conventional free air thermal current Ith (A)	6A
- conventional enclosed thermal current Ithe (A)	N/A
- rated operational current le (A)	6A
Rated frequency (Hz)	50/60Hz
Utilization category	AC-12, AC-13
Short-circuit characteristic:	
- rated conditional short-circuit current (kA)	1kA
- kind of protective device:	250V 10kA gG Fuse according to EN60269
Electrically separated contact elements:	N/A (state by manufacturer)
Actuating quantities for pilot switches	See technical document from manufacturer.
Pilot switches having two or more contact elements:	N/A
Indication of contact elements of same polarity:	N/A
IP code, in case of an enclosed control device	IP67
Pollution degree	3
Suitability for isolation, with the symbol 07-13-06 of IEC 60617-7:	N/A



N/A
P (Pass)
F (Fail)
2022-08-01
2022-08-01 ~ 2022-11-11
pended to the report. e report.
ed as the decimal separator.
ECEE 02:
☐ Yes ⊠ Not applicable
e General product information section.
KG Auto Co. Ltd.
45, Sojeongsandan 4-ro, Sojeong-myeon, Sejong- si, Republic of Korea



5	PRODUCT INFORMATION		
5.2	Marking		Р
	Data shall be preferably marked on the equipment:		
	a - manufacturer's name or trademark	KG Auto	Р
	b - type designation or serial number	See page. 4	Р
	Data shall be included on the nameplate, or on the equipment, or in the manufacturer's published literature:		
	c - number of this standard	EN 60947-5-1	Р
	d - rated operational voltages	250V	Р
	e - utilization category and rated operational currents, at the rated operational voltages of the control circuit device	AC-12,AC-13 250Va.c 6A	Р
	f - rated insulation voltage:	300V	Р
	g - rated impulse withstand voltage	4kV	N/A
	h - vacant		N/A
	i - IP code, in case of enclosed control circuit device	IP67	Р
	j - pollution degree	3	N/A
	k - type and maximum ratings of short-circuit protective device	250V 10kA gG Fuse according to EN 60269	N/A
	I - conditional short-circuit current		N/A
	m - suitability for isolation, where applicable, with the symbol S00288 of IEC 60617		N/A
	n - indication of contact elements of same polarity		N/A
	Marking of data under n) shall be included on the nameplate of the control circuit		N/A
	device in order to ensure proper wiring at installation.		
	 o) length of insulation to be removed before insertion of the conductor into the terminal. 		N/A
	 p) for non-universal screwless terminals: - "s" or "sol" for terminals declared for rigid- solid conductors; - "r" for terminals declared for rigid (solid and stranded) conductors; - "f" for terminals declared for flexible conductors. 		N/A
	The indication "s", "sol", "r" or "f" for non-universal screwless terminals shall be marked on the		N/A
	device or, if the space available is not sufficient, on the smallest package unit or in technical information provided with the product		
522	Terminal identification and marking (see 7.1.8.4 of IE	 C 60947-1)	
0.2.2	Clearly and permanently identified according IEC 60445 and Annex L, unless superseded by relevant standard.		Р

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 9 of 65 page



<u></u>	Neutral terminal identified by letter	Ν	N/A	
	Protective earth terminal identified by letter		N/A	
5.2.3	Functional markings			
	Actuators may be identified by symbols in the form of engravings, but if a stop button carries any symbol engraved or marked this symbol shall be a circle or oval		N/A	
	Letters or words may be used where space is available		N/A	
	Symbols shall be in accordance with IEC 60417		N/A	
5.2.4	Emergency stop			
	Actuator shape and colour, background colour and direction of unlatching for emergency stop devices with mechanical latching function shall be in accordance with 4.2 of IEC 60947-5-5		Ρ	
5.2.5	Operating diagram			
5.2.5.1	General			
	As rotary switches may have multiplicity of contacts elements and a multiplicity of actuator positions, it necessary that the manufacturer indicates the relationship between the actuator positions and the associated contact elements position	No rotary switches	N/A	
5.2.5.2	Position indication and contact position			
	Sub clause 7.1.6.1 of IEC 60947-1 applies		N/A	
	The position indication shall be clear, and the associated text or symbols shall be indelible and easily legible	Symbol is indelible and easily legible	N/A	
5.2.5.3	Terminal markings for operating diagrams			
	Terminal markings shall be clearly identifiable with respect to the operating diagram (see also Annex M)		N/A	
5.2.6	Time delay markings			
	The manufacturer shall indicate, for each time-delay contact element, the characteristic of the delay, according to 2.4.1.1 or 2.4.1.2	No time delay contact element	N/A	
5.3	Instructions for installation, operation and maintenance			
	The manufacture shall specify, in his documents or catalogues:			
	- the conditions for installation, operation and maintenance, if any, of the equipment during operation and after a fault	Installation, operation and maintenance conditions are specified in the catalogue or manual	Ρ	
	- the specify the measures to be taken with regard to EMC, if any,	Not EMC relevant	N/A	

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 10 of 65 page



- equipment only suitable in environment A shall provided with the following notice	This product has been designed for environment B may cause unwanted electromagnetic disturbances in which case the user may be required to take adequate mitigation measures.	N/A
- if necessary, the instructions for transport, installation and operation of the equipment shall indicate the measures that are particular importance for the proper and correct installation, commissioning and operation of the equipment.		Ρ



6	Normal service, mounting and transport conditio	ns	
6.1.1	Ambient temperature		
	Ambient air temperature does not exceed +40 °C and its average over 24 hours does not exceed $+35^{\circ}$ C and the lower limit is -5° C		Р
6.1.2	Altitude		
	Altitude of side of installation does not exceed 2000m		Р
6.1.3	Atmospheric conditions		
6.1.3.1	Relative humidity does not exceed 50 % at max temp +40 °C, higher rel. hum may at lower temperatures e.g. 90% at +20 °C		Р
6.1.3.2	Pollution degree		
	Unless otherwise stated, equipment for: - industrial use shall have a degree 3, depending upon micro-environment - household and similar shall have degree 2	Pollution degree 3	Р
6.1.4	Shock and vibration		
	Under consideration		
6.2	Conditions during transport and storage		
	Under consideration		
6.3	Mounting		
	According manufacturer's instruction	See manual.	Р
6.3.1	Mounting of single hole mounted devices		
	Dimensions according Table 2		N/A
6.3.1.1	Location of key recess (if any)		
	Dimensions according Table 3		N/A
6.3.1.2	Range of panel thickness		
	The device shall be capable of being mounted on any thickness between 1 and 6 mm		N/A
6.3.1.3	Grouping of devices		
	The distances a between the mounting centres in the same row and b between the centre lines of the rows shall be not less than those given in table 3. Distances a and b may be interchanged		N/A



7	CONSTRUCTIONAL AND PERFORMANCE REQUIREMENTS		
7.1	Constructional requirements		
7.1.1	General		
	Sub clause 7.1 of IEC 60947-1 applies except for 7.1.2, 7.1.3, 7.1.7, 7.1.9 and 7.1.13, and with the following additions:		Р
7.1.2	Materials		
7.1.2.2	Glow-wire testing		
		Test method 7.1.2.3 of IEC 60947-1 used	N/A
7.1.2.3	Test based on flammability category		
		See Table Critical components information	Р
7.1.3	Current-carrying parts and their connection		
	No contact pressure through insulating materials		Р
7.1.4	Clearances and creepage distances		
	Clause 7.1.4 of IEC 60947-1 applies		
	Clearances		
	Minimum values are given in Table 13 and Table 15 of IEC 60947-1		
	Rated impulse withstand voltage	See test sequence I	
	Minimum clearance - Case B (mm)	Required : 5.5 m	
	Minimum clearance - Case A (mm)	Required : 2 mm	
	Measured clearances (mm):	Measured: 12 mm	Р
	Creepage distances		
	Pollution degree	3	
	Comparative tracking index (V):	175	
	Material group:	Illa	
	Rated insulation voltage Ui (V):	300V	
	Minimum creepage distances (mm)	10	
	Measured creepage distances (mm):	21	Р
7.1.5	Actuator		
7.1.5.1	Insulation		
	Clause 7.1.5.1 of IEC 60947-1 applies	Ui=300V	Р
7.1.5.2	Direction		
	Clause 7.1.5.2 of IEC 60947-1 applies		Р
7.1.5.3	Actuating force (or moment)		
			Р
7.1.5.4	Limitation of rotation (of rotary switch)		

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 13 of 65 page



age: 13 c	of 65 page		
	When actuators with limited or unidirectional movement are used, they shall be fitted with robust means of limitation, capable of withstanding five times the actual maximum actuating moment.		N/A
7.1.5.5	Emergency stop		
	The actuator shall preferably latch in the actuated position with the control contact open. This latching shall be released by a separate action, e.g. by pulling, rotation, or by means of a key.		N/A
7.1.6	Indication of the contact position		
	Clause 7.1.6 of IEC 60947-1 applies		Р
7.1.7	Conditions for control switches suitable for isolation		
	A control switch suitable for isolation shall be manually operated with a direct opening action (see Annex K) and shall comply with the isolating function in the open position (see 2.1.19 and 7.1.7 of IEC 60947-1).		N/A
	The open position of a control switch suitable for isolation shall be a position in which the switch can remain when no actuating force is applied.		N/A
	In order to avoid unintentional reclosing, it shall be possible to prevent the operation of the control switches suitable for isolation when the contact elements are in the open position. This may be obtained by padlocking or by a latch which shall only be releasable by a special tool or key.		N/A
7.1.8	Terminals		
		See clause 8.2.4	Р
7.1.10	Provisions for protective earthing		
	Clause 7.1.10 of IEC 60947-1 applies		N/A
7.1.11	Enclosures for equipment		
	Clause 7.1.11 of IEC 60947-1 applies		Р
7.1.12	Degree of protection of enclosed equipment	IP 67 is declared by the manufacturer	
	Degree of protection:	IP 67	
	Test for first characteristic	6	
	Test for first numeral :	□ 1: □ 2: □ 3: □ 4: □ 5: ⊠ 6:	Ρ
	Test for second characteristic	7	



ige: 14	of 65 page		
	Test for second numeral:	□ 1: □ 2: □ 3: □ 4: □ 5: □ 6: ⊠ 7: □ 8:	Ρ
7.1.14	Class II control circuit devices	L 0.	
	These devices shall not be provided with means for protective earthing (see IEC 61140)		N/A
	For class II control circuit devices insulated by encapsulation, see Annex F	See annex F	N/A
7.1.15	Requirements for control devices with integrally conr	nected cables	
		See annex G	N/A
7.2	Performance requirements		
	Subclauses 7.2.1.1 and 7.2.2 of IEC 60947-1 apply with the following additions:		Р
7.2.1.2	Limits of operation of contactor relays		
	The limits of operation for contactor relays shall be in accordance with IEC 60947-4-1	See clause 8.3.3.2	N/A
7.2.3	Dielectric properties		
	Subclause 7.2.3 of IEC 60947-1 applies with the following addition	See clause 8.3.3.4	Р
	For class II control circuit devices insulated by encapsulation	See Annex F	N/A
7.2.4	Ability to make and break under normal and abnorma	al load conditions	
7.2.4.1	Making and breaking capacities		
	Making and breaking capacities under normal conditions as state in table 4	See clause 8.3.3.5.3	Р
	Making and breaking capacities under abnormal conditions as state in table 5	See clause 8.3.3.5.4	Р
7.2.4.3	Durability		
	Sub-clause 7.2.4.3 of IEC 60947-1 applies with the following additions:		
	Mechanical durability	See Annex C	N/A
	Electrical durability	See Annex C	N/A
7.2.5	Conditional short-circuit current		
	The switching element shall withstand the stresses resulting from short-circuit current under the conditions specified in 8.3.4		Р
7.2.7	Additional requirements for control switches suitable	for isolation	
L			

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 15 of 65 page



.90			
	Control switches suitable for isolation shall be tested according to 8.3.3.4 of IEC 60947-1 with a value of test voltage as specified in Table 14 or IEC 60947-1 corresponding to the rated impulse withstand voltage Uimp declared by the manufacturer.	No isolation switches	N/A
	Other additional requirements applicable to such control switches are under consideration	No isolation switches	
7.2.8	Maximum recovery time		
	For equipment incorporating electronic circuits the maximum recovery time and the measuring method shall be stated by the manufacturer	No such parts.	N/A
7.3	Electromagnetic compatibility (EMC)		
	Subclause 7.3 of IEC 60947-1 applies with the following additions:		N/A
	The control circuit device to be tested shall have all the essential design details of the type which it represents and shall be in a clean and new condition.		N/A
	The EMC tests shall be conducted at rated operational voltage Ue, or if the rated operational		N/A
	voltage is given as a range, then the test shall be conducted at a voltage which represents the worst case condition.		
	Maintenance or replacement of parts during or after a testing cycle is not permitted.		N/A
	The products covered by this standard are intended for use in environment A.		N/A
	Contactor relays incorporating electronic circuits shall follow the requirements of 8.3.2.2 of IEC 60947-4-1		N/A

 Report. No.:
 TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 16 of 65 page

8.3.1	TEST SEQUENCE I (sample No. 1)	
Test No. 1	- operating limits of contactor relays (8.3.3.2)	
Test No. 2	- temperature rise (Clause 8.3.3.3.)	
Test No. 3	- dielectric properties (Clause 8.3.3.4)	
Test No. 4	- mechanical properties of terminals (8.2.4 of IEC 60947-1)	
8.3.3.2	Operating limits of contactor relays	
8.3.3.2.1	Power-operated equipment:	
8.2.1.2.1	Electromagnetic contactors and starters	
	rated control supply voltage Us (V):	
	frequency (Hz)	
	declared ambient temperature(>40 °C) for 100% Us	
	limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage Us . :	N/A
	limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c	N/A
	ambient temperature(-5 °C) for 100% Us	
	limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage Us . :	N/A
	Limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c:	N/A
8.2.1.2.2	Contactors and starters with electronically controlled electromagnet	
	Rated control supply voltage Us (V)	
	Frequency (Hz)	
	Declared ambient temperature(>40 °C) for 100% Us	
	Limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage Us .:	N/A
	Limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c	N/A
	Ambient temperature(-5 °C) for 100% Us	
	Limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage Us .:	N/A
	Limits of drop out and open fully are: 75% to 20% for a.c. and 75% to 10% for d.c:	N/A
8.2.1.2.3	Electro-pneumatic contactors and starters	
	Rated air supply pressure(Bar):	
	Declared ambient temperature(>40 °C) for 100% of the rated air supply pressure(Bar)	
	Limits of close satisfactorily at any value between 85% and 110% of rated air supply pressure(Bar):	N/A



 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 17 of 65 page



ge: 17	of 65 page	
	Limits of drop out and open fully are: 75% to 10% of rated air supply pressure(Bar):	N/A
	Ambient temperature(-5 °C) for 100% of the rated air supply pressure(Bar)	
	Limits of close satisfactorily at any value between 85% and 110% of rated air supply pressure(Bar):	N/A
	Limits of drop out and open fully are: 75% to 10% for the rated air supply pressure(Bar)	N/A
8.3.3.3	Temperature rise	
	ambient temperature 10-40 °C 20	
	test enclosure W x H x D (mm x mm x mm): 300 x 300 x 300	
	material of enclosure: Plastic	
	NO-contacts, test conditions:	
	- rated operational current le (A): Tested by NC contact	N/A
	- cable cross-section (mm²):	N/A
-	- cable length (m):	N/A
	- temperature rise of NO terminals (K):	N/A
	NC-contacts, test conditions:	
	- rated operational current le (A) : 6 A	Р
	- cable cross-section (mm ²): 1	Р
-	- cable length (m):	Р
	- temperature rise of NC terminals (K):	Р
	Coils and electromagnets, test conditions:	
	- rated control supply voltage Us (V / Hz): No such parts.	N/A
-	- Class of insulating material: No such parts.	N/A
-	- temperature rise of coil and electromagnets (K) : No such parts.	N/A
8.3.3.4	Dielectric properties	
	Test of dielectric properties, impulse withstand voltage (Uimp indicated):	
	- verification by measurement of clearances instead of testing	Р
	- rated impulse withstand voltage (V):	N/A
	- test Uimp auxiliary circuits (kV):	N/A
-	Test of dielectric properties, dielectric withstand voltage (Uimp not indicated):	
-	- rated insulation voltage (V)	N/A
	- control and auxiliary circuits, test voltage (V) for 60 sec	N/A
8.2.4	Mechanical and electrical properties of terminals	
8.2.4.2	Mechanical strength of terminals	
	maximum cross-sectional area of conductor (mm²) : 1	Р
	diameter of thread (mm): 4	Р
	torque (Nm): 1.2	Р
l		

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 18 of 65 page



<u>ye.</u> 18			
	5 times on 2 separate clamping units		Р
8.2.4.3	Testing for damage to and accidental loosening of co	nductor (flexion test)	
	conductor of the smallest cross-sectional area (mm ²):	1 (smallest = largest)	Р
	number of conductor of the smallest cross section . :	1	Р
	diameter of bushing hole (mm):	6.4	Р
	height between the equipment and the platen (mm)	260	Р
	mass at the conductor(s) (kg):	0.4	Р
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		Р
8.2.4.4	Pull-out test		
	force (N):	35	Р
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		Р
8.2.4.3	Flexion test		
	conductor of the largest cross-sectional area (mm ²) :		N/A
	number of conductor of the largest cross-section :		N/A
	diameter of bushing hole (mm):		N/A
	height between the equipment and the platen (mm)		N/A
	:		
	mass at the conductor(s) (kg):		N/A
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		N/A
8.2.4.4	Pull-out test		
	force (N):		N/A
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		N/A
8.2.4.3	Flexion test		
	conductor of the largest and smallest cross-sectional area (mm²):		N/A
	number of conductor of the smallest cross sectional, number of conductor of the largest cross sectional . :		N/A
	diameter of bushing hole (mm):		N/A
	height between the equipment and the platen (mm)		N/A
	mass at the conductor(s) (kg):		N/A
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		N/A
8.2.4.4	Pull-out test		
	force (N):		N/A

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 19 of 65 page



	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit	N/A
8.2.4.5	Test for insertability of unprepared round copper conductors having the	
	maximum cross-section	
	The test shall be carried out using the appropriate gauge form A or form B specified in Table 7.	N/A
	The measuring section of the gauge shall be able to penetrate freely into the terminal aperture	N/A
	Table 7).	
8.2.4.7	Alternatively, the test can be carried out by inserting the largest conductor of type and rated cross-section among those recommended by the manufacturer, the diameter of which 	N/A
	If terminals are used which are gualified according	
	to IEC 60999-1 and the operating conditions of the terminals in the device are according to the operating conditions specified by the manufacturer of the terminals, then the test does not need to be performed.	N/A
	Sub clause 8.2.4.7 of IEC 60947-1 applies with the following changes:	N/A
	 The test shall be done on the connecting device equipped with the clamping units; The number of specimens shall be at least 8; The test shall be done as a single 8 test: Eight clamping units shall be tested to the declared voltage drop; If the number of failed clamping units does not exceed two, the test is considered passed. 	N/A
	test current (A):	N/A
	voltage drop < 15 mV. (V)	Ν/Δ
8.2.4.8	Ageing test for screwless-type clamping units	
	If terminals are used which are qualified according to IEC 60999-1 and the operating conditions of the terminals in the device are according to the operating conditions specified by the manufacturer of the terminals, then the test does not need to be performed.	N/A
	Subclause 8.2.4.8 of IEC 60947-1 applies with the	N/A
	Tollowing changes: The test shall be done on the connecting device equipped with the clamping units.	N/A
	test current (A)	N/A
	maximum temperature for the temperature cycles shall be 40°C. Max. temperature (°C)	N/A

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 20 of 65 page

	"7	YGERCT
--	----	--------

~		
	voltage drop \leq 22,5 mV or 1,5 times	the value N/A
	measured after the 24th cycle. (V)	

11	CONSULTING & TESTING	
	IGER	

8.3.1	TEST SEQUENCE II (sample No. 2)		
Test No. 1	- Making and breaking capacities of switching elemer (8.3.3.5.3)	ts under normal conditions	
Test No. 2	- Dielectric verification (8.3.3.5.6.b)		
8.3.3.5.3	Making and breaking capacities of switching elements	s under normal conditions	
	contact element (figure / form):	4X	
	contact polarity:		
	utilization category (AC / DC)	AC-13	
	rated operational voltage Ue (V)	250 V	
	rated operational current le (A) or power (kW) :	6 A	
No.1	- test voltage U/Ue = 1,1 (V):	L1: 275 V	Р
	- power factor/time constant	L1: cosphi = 0.65	Р
	- make operations: test current I/Ie (A)	L1: 12A	Р
-	- break operations: test current I/Ie (A):	L1: 6A	Р
	- a.c. test: Inductor shunted by a resistor taking 3% of the total power consumed		Р
	- d.c. test: test current increase from zero to steady- state value within limits of figure 9		
	- on-time (ms):	50	Р
	- operating cycles per minute:	6	Р
	- number of operating cycles:	50	Р
	- test voltage U/Ue = 1,0 (V):	L1: 250	Р
	- power factor/time constant:	L1: cosphi = 0.65	Р
	- make operations: test current I/Ie (A)	L1: 12A	Р
	- break operations: test current I/Ie (A)	L1: 6A	Р
No. 2	- on-time (ms):	50	Р
-	- operating cycles per minute:	Rapidly	Р
	- number of operating cycles:	10	Р
No. 3	- on-time (ms):	50	Р
	- operating cycles per minute:	60	Р
	- number of operating cycles:	990	Р
No. 4	- on-time (ms):	50	Р
	- operating cycles per minute:	6	Р
	- number of operating cycles:	5000	Р
	Behaviour and condition during and after the test:	1	
	- no electrical or mechanical failures	No electrical or mechanical failures	Р

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 22 of 65 page



	- no contact welding or prolonged arcing	No contact welding or prolonged arcing	Р
	- no blowing of the fusible element in the earth circuit	No earth circuit	Р
8.3.3.5.6.b	Dielectric verification:		
	dielectric test voltage (V) 2 xUe with a min.of 1000V:	1000	Р

8.3.1	TEST SEQUENCE III (sample No. 3)		
Test No. 1	- Making and breaking capacities of switching elements under abnormal conditions (8.3.3.5.4)		
Test No. 2	- Dielectric verification (8.3.3.5.6.b)		
8.3.3.5.4	Making and breaking capacities of switching element	s under abnormal conditions:	
	contact element (figure / form):	4X	
	contact polarity:		
	utilization category (AC / DC):	AC-13	
	rated operational voltage Ue (V):	250 V	
	rated operational current le (A) or power (kW) :	6 A	
	Conditions, make/break operations:		
	- test voltage U/Ue = 1,1 (V):	L1: 275	Р
	- power factor/time constant:	L1: cosphi – 0.65	Р
	- make operations: test current I/Ie (A)	L1: 60	Р
	- break operations: test current I/Ie (A):	L1: 6.6	Р
	- a.c. test: Inductor shunted by a resistor taking 3% of the total power consumed		Р
	- d.c. test: test current increase from zero to steady- state value within limits of figure 9		
	- on-time (ms):	50	Р
	- operating cycles per minute:	6	Р
	- number of operating cycles:	10	Р
	Behaviour and condition during and after the test:		
	- no electrical or mechanical failures	No electrical or mechanical failures	Р
	- no contact welding or prolonged arcing	No contact welding or prolonged arcing	Р
	- no blowing of the fusible element in the earth circuit	No earth circuit	Р
8.3.3.5.6.b	Dielectric verification:	1	
	dielectric test voltage (V) 2 xUe with min.of 1000V:	1000	Р



 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 24 of 65 page

	"7	CONSULTING & TESTING	CT	
--	----	----------------------	----	--

8.3.1	TEST SEQUENCE IV (sample No. 4)		
Test No. 1	- Performance under conditional short-circuit current ((8.3.4)	
Test No. 2	- Dielectric verification (8.3.3.5.6.b)		
8.3.4	Performance under conditional short-circuit current		
	contact element (figure / form):	4X	
	contact polarity:		
	type of SCPD:	250V 10kA gG Fuse according to EN 60269	
	ratings of SCPD (A / V):	See above.	
	prospective current (kA):	1 kA	
	test voltage (V) U/Ue = 1,1 (V):	L1 : 275 V	Р
	r.m.s. test current obtained (kA):	L1 : 1 kA	Р
	power factor (max. 0,7):	0.65	Р
	first CO operation by closing the separate making switch: test Ip / I²dt (kA / kA²s):		Р
	time interval between test (min. 3 min):	3 min	Р
	second CO operation by closing the separate making switch: test lp / l²dt (kA / kA²s):		Р
	time interval between test (min. 3 min)	3 min	Р
	third making operation to closed switching elements: test lp / l²dt (kA / kA²s):		Р
	Behaviour of the equipment during the test:		
	switching elements open by the normal actuating system		Р
8.3.3.5.6.b	Dielectric verification:		
	dielectric test voltage (V) 2 xUe with min.of 1000V:	1000	Р

8.3.1	TEST SEQUENCE V (sample No. 5)	
Test No. 1	- Degree of protection of enclosed control circuit-devices (Annex C of IEC 60947-1)	
Test No. 2	2 - Verification of actuation force or moment (8.2.5)	
Annex C	Degree of protection of enclosed control circuit-devices	
	The enclosed control circuit devices shall comply with the requirements of Annex C of IEC60947-1	Р
8.2.5	Verification of actuation force or moment	
	When required in 7.1.5.3, the minimum actuating force or moment shall be tested during sequence V of 8.3.1.	Р
	The performance shall be as stated in 7.1.5.3	
7.1.5.3	Actuating force (or moment)	
	The force (or moment) required to operate the actuator shall be compatible with the intended application, taking into account the size of the actuator, the type of enclosure or panel, the environment of the installation and the use for which it is intended	P
	The minimum starting force (or moment) shall be sufficiently large to prevent inadvertent operation; e.g. push-buttons and rotary switches to be used with enclosures complying with degrees of protection IPX5 or IPX6 shall not become actuated when hit by the jet of water applied during the test of the enclosed equipment.	N/A
	Minimum force (N)	N/A
	Minimum moment (Nm)	N/A



8.3.1.	TEST SEQUENCE VI (sample No. 6)		
Test No. 1	- Measurement of clearances and creepage distance	s (7.1.4 of IEC 60947-1)	
Test No. 2	- Verification of limitation of rotation of a rotary switch	(8.2.6)	
7.1.4	Measurement of clearances and creepage distances		
	Clearances and creepage distances	See clause 7.1.4	Р
8.2.6	Verification of limitation of rotation of a rotary switch		
	When this test is required in 7.1.4.5, it shall be tested during sequence VI of 8.3.1		N/A
	The test sample shall be mounted according to the manufacturer's instructions		
7.1.4.5	Limitation of rotation (of a rotary switch)		
	When actuators with limited or unidirectional movement are used, they shall be fitted with robust means of limitation, capable of withstanding five times the actual maximum actuating moment		N/A
8.2.6	The operating moment shall be measured five times and the maximum value recorded (Nm):		N/A
	The maximum moment value, multiplied by five, shall be applied to the actuator by forcing it against the means of limitation. The moment shall be applied for 10 s (Nm)		N/A
	Means of limitation has not moved, become loose or prevented the actuator's normal operation		N/A



 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 27 of 65 page



8.4	TEST FOR EMC		
8.4.1.	General		
	Control circuit devices having only passive components are not required to be tested.		N/A
	Subclauses 8.3.2.1 of IEC 60947-1 and 8.3.2.4 of		
	IEC 60947-1 apply with the following additions:		
	Control circuit devices intended to be mounted in a hole of a panel shall be mounted in a		N/A
	hole which is located in the centre of a grounded square metal plate.		
	Control circuit devices intended to be mounted on surfaces or on standard rails shall be mounted directly on the grounded square metal plate or on the standard rail which is fixed on the grounded square metal plate.		N/A
	Control circuit devices intended to be mounted in associated metal enclosures shall be mounted in the grounded metal enclosure with the smallest dimension available or on the grounded square metal plate, whichever		N/A
	configuration yields the worst results.		
	(300 \pm 50) mm and the thickness 1,5 $_{0}^{+0.5}$ mm.		N/A
	If not required otherwise by horizontal standard the connecting leads shall be $2_0^{+0,1}$ m. If the length of the connecting leads is other than 2 m. Cable length (m)		N/A
	For control circuit devices not having integral cables, the type of cable or wire used shall be specified by the manufacturer: Type of cable:		N/A
	The test sample shall be in the ON-status or in the OFF-status, whichever is the worse. Tested state :	ON / OFF	N/A
	Where a range of control circuit devices are made according to the same principle and design, and using the same type of components, tests may be performed on representative samples.		N/A
8.4.2	Immunity	·	
8.4.2.1	Electrostatic discharges.		
	The test shall be performed according to IEC 61000-4-2 and 7.3.2.4, and shall be repeated 10	See	N/A
	times at each measuring point, with a minimum time interval of 1 s between pulses.		
8.4.2.2	Radiated radio-frequency electromagnetic fields		
	The test shall be performed according to IEC 61000-4-3 and 7.3.2.5.	See	N/A
8.4.2.3	Electrical fast transients/bursts		
	The test shall be performed according to IEC 61000-4-4 and 7.3.2.6, with all the connecting	See	N/A
	leads placed in the capacitive coupling clamp.		
8.4.2.4	Surges		

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 28 of 65 page



. <u>ye.</u> 20	or op page		
	The test shall be conducted using the methods of IEC 61000-4-5. Capacitive coupling shall be	See	N/A
	preferred. Surges shall be supplied between:		
	a) between terminals intended to be connected to the power supply;		N/A
	b) between each output terminal and each terminal intended to be connected to the power supply		N/A
	The test voltage values are those of Table 8 but shall not exceed the corresponding <i>U</i> _{imp} value(s) given by the manufacturer following 7.2.3 of IEC 60947-1. Test voltages (V)		N/A
	The repetition rate shall be one surge per minute, with the number of pulses being five positive and five negative.		N/A
8.4.2.5	Conducted disturbances induced by radio-frequenc	y fields	
	The test shall be performed according to IEC 61000-4-6 and 7.3.2.8.	See	N/A
8.4.2.6	Power-frequency magnetic fields		
	The test shall be performed according to IEC 61000-4-8 and 7.3.2.9.	See	N/A
8.4.2.7	Voltage dips and interruptions		
	The test shall be performed according to IEC 61000-4-11 and 7.3.2.10.	See	N/A
8.4.3	Emission		
	The test shall be performed according to CISPR 11, group 1, class A, and 7.3.3.	See	N/A



Annex C of IEC 60947-1	DEGREE OF PROTECTION OF ENCLOSED CONTROL CIRCUIT-DEVICES		
C.1	Scope		
	This annex applies to degrees of protection of enclosed switchgear and control gear at rated voltages not exceeding 1000 V a.c. or 1500 V d.c. hereafter referred as "equipment"	Rated voltage : 250 Va.c	Р
C.2	Object		
	Clause 2 of IEC 60529 applies with additional requirements of this annex	Applied	Р
C.3	Definitions		
	Clause 3 of IEC 60529 applies except that "Enclosure" is replaced by the following:	Considered	Р
	"A part providing a specified degree of protection of equipment against certain external influences and a specified degree of protection against approach to or contact with live parts and moving parts"	Considered	Р
C.4	Designation		
	Clause 4 of IEC 60529 applies except for letters H, M and S		N/A
C.5	Degrees of protection against access to hazardous parts and against ingress of solid foreign objects indicated by the first characteristic numeral		
	Clause 5 of IEC 60529 applies		Р
C.6	Degrees of protection against ingress of water indicated by the second characteristic numeral		
	Clause 6 of IEC 60529 applies		Р
C.7	Degrees of protection against access to hazardous p letter	arts indicated by the additional	
	Clause7 of IEC 60529 applies		N/A
C.8	Supplementary letters		
	Clause 8 of IEC 60529 applies		N/A
C.9	Examples of designations with IP Code		
	Clause 9 of IEC 60529 applies		Р
C.10	Marking		
	Clause 10 of IEC 60529 applies with the following addition:		Р
	If the IP Code is designated for one mounting position only, it shall be indicated by the symbol 0623 of ISO 7000 placed next to the IP Code specifying this position of the equipment, e.g. vertical		N/A
C.11	General requirements for the tests		
C.11.1	Clause 11.1 of IEC 60529 applies		Р

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 30 of 65 page



age: 30 d	bi ob page	
C.11.2	Clause 11.2 of IEC 60529 applies with the following additions:	Р
	All tests are made in the unenergized state	Р
	Certain devices(e.g. exposed faces of push-buttons) can be verified by inspection	N/A
	The temperature of the test sample shall not deviate from the actual temperature by more than 5 K	Р
	Where equipment is mounted in an empty enclosure which already has an IP code the following requirements apply:	
	a) For IP1X to IP4X and additional letters A to D	N/A
	This shall be verified by inspection and compliance with the enclosure manufacturer's instructions	
	b) For IP6X dust test	N/A
	This shall be verified by inspection and compliance with the enclosure manufacturer's instructions	
	c) For IP5X dust test and IP1X to IP8X water tests testing of the enclosed equipment is only required where the ingress of dust or water may impair the operation of the equipment	N/A
C.11.3	Sub clause 11.3 of IEC 60529 applies with the following addition:	N/A
	Drain and ventilating holes are treated as normal openings	N/A
C.11.4	Clause 11.4 of IEC 60529 applies	Р
C11.5	Where an empty enclosure is used as a component of an enclosed equipment, Clause 11.5 of IEC 60529 applies	N/A
C.12	Degrees of protection against access to hazardous parts indicated by the first characteristic numeral	
	Clause 12 of IEC 60529 applies except for 12.3.2	Р
C.13	Degrees of protection against ingress of solid foreign objects indicated by the first characteristic numeral	
	Clause 13 of IEC 60529 applies except for	Р
C.13.4	Dust test for first characteristic numerals 5 and 6	
	Enclosed equipment having a degree of protection IP5X shall be tested according to category 2 of 13.4 of IEC 60 529	N
	Enclosed equipment having a degree of protection IP6X shall be tested according to category 1 of 13.4 of IEC 60 529	Р
C.13.5.2	Acceptance conditions for first characteristic numeral 5	
	The following text to be added:	
	Where dust deposits could raise as to the correct functioning and safety of the equipment, a preconditioning and a dielectric test shall be conducted as follows:	N/A

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 31 of 65 page



0		
	The preconditioning, after dust test, shall be verified by test Ca: damp heat, steady state, according to IEC 60068-2-3, under the following conditions.	N/A
	The equipment shall be prepared so that the dust deposits are subjected to the test by leaving open the lid and/or removing parts, where possible without the aid of tool	N/A
	Before being placed in the chamber the equipment shall be stored at room temperature at least 4 h before the test	N/A
	The test duration shall be 24 consecutive hours	N/A
	After this period the equipment is to be removed from the chamber within 15 min and submitted to a power-frequency dielectric test for 1 min, the value being 2 Uemax with a minimum of 1000 V (V)	N/A
C.14	Tests for protection against ingress of water indicated by the second characteristic numeral	
C.14.1	Clause 14.1 of IEC 60529 applies	Р
C.14.2	Clause 14.2 of IEC 60529 applies	Р
C.14.3	Clause 14.3 of IEC 60529 applies with following addition:	Р
	The equipment's then submitted to a power- frequency dielectric test for 1 min, the value being 2 Uemax with a minimum of 1000 V (V)	Р
C.15	Tests for protection against access to hazardous parts indicated by additional letter	
	Clause 15.1 of IEC 60529 applies	N/A
C.16	Summary of responsibilities of relevant technical committees	



Annex C	SPECIAL TESTS - DURABILITY TESTS	
C.1	General	
C.1.1	Durability declaration	
	The special durability tests described in this annex are conducted at the discretion of the manufacturer	
	Declared number of operating cycles by the manufacturer:	
	- mechanical:	N/A
	- electrical:	N/A
C.1.2	Test procedures	
	As stated in 8.3.2.1 and at a rate equal or higher than that declared by the manufacturer	N/A
	The moving parts of the device shall reach their maximum operating positions in both directions, as recommended by the manufacturer	N/A
C.1.2.2	Single 8 test	
	Eight control circuit devices shall be tested to the declared number of operating cycles	N/A
	If the number of failed devices does not exceed two, the test is considered passed	N/A
C.1.2.3	Double 3 test	
	Three control circuit devices shall be tested to the declared number of operating cycles	N/A
	The test is considered passed if there is no failure, and failed if there is more than one failure.	N/A
	Should there be only one failure, then three additional control devices are tested to the declared number of operating cycles and providing there is no additional failure, the test is considered passed.	N/A
C.1.3	Failure criteria	
	During the tests described in C.2.2 and C.3.2, there shall be no electrical and/or mechanical failures	N/A
	Following the tests, the switching element shall pass Utest (V): the dielectric test of 8.3.3.4 with a rated test voltage equal to 2 Ue with a minimum of 1000 V (V)	N/A
C.2	Mechanical durability	
C.2.1	General	
	The mechanical durability of a control circuit device is defined as the number of no-load operating cycles which will be attained or exceeding by 90 % of all devices tested without repair or replacement of any part.	N/A
C.2.2	Test procedures	
	Tests are carried out according to C.1.2.	N/A

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 33 of 65 page



ge: 33 (of 65 page		
	During the test, periodically the contacts shall be checked at any voltage and current, selected by the manufacturer, and there shall be no failure	(see C.1.3)	N/A
C.3	Electrical durability		
C.3.1	General		
	Electrical durability of a control device is defined as the number of on-load operating cycles which will be attained or exceeded by 90% of all devices tested, without repair or replacement of any part		N/A
C.3.2	Test procedures		
C.3.2.1	General		
	Electrical durability tests are carried out by operating the device under the conditions defined in table C.1, in accordance with C.3.2.2 for a.c. or with C.3.2.3. for d.c.		N/A
	Each mechanical operation cycle shall include an interruption of the test current		N/A
	The ON-duration of the current shall not more 50% and not-less than 10% of an operating cycle (ms) :	ON-duration (ms):	N/A
	If the test circuit shown in figure C.1 is used, the ON- duration of current at 10 times le shall not cause overheating		N/A
	Alternatively these test may be performed on the actual load for which the control switch is intended		N/A
C.3.2.2	AC tests		
	Used circuit:	[] Figure C.1 [] Figure C.2	N/A
	The circuit to be used as shown in fig C.1:		N/A
	- Making circuit consisting air-cored inductor, in series with resistor, power factor of 0,7:	U test (V): I test (A): Pf:	N/A
	- Breaking circuit consisting air-cored inductor, in series with resistor, parallel damping resistor in which flows 3 % of breaking current, power factor of 0,4	U test (V): I test (A): Pf: R (Ohm):	N/A
	If the contact element has a bounce time less than 3 ms, the test may be made with the simplified circuit shown in Figure C.2	Bounce time (ms):	N/A
C.3.2.3	DC Tests		
	Used inductor:	[] air-cored [] iron-cored	N/A
	The circuit to be used as shown in fig C.1:		N/A
	- circuit consisting air-cored inductor, in series with resistor, parallel damping resistor across the complete circuit in which flows 1 % of test current power factor of $T_{0,95}$ or	U test (V): I test (A): R (Ohm): T _{0,95} (ms):	N/A

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 34 of 65 page



ı a	ge. 54 bi be page		
	-circuit consisting iron-cored inductor, in series with	U test (V):	N/A
	resistor, power factor of $T_{0,95}$	I test (A):	
	T _{0,95} = 6 x P for P< 50 W	Pf:	
	$T_{0,95}$ = 300 ms for P = 50 W	R (Ohm):	

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 35 of 65 page



Annex E	ITEMS SUBJECT TO AGREE BETWEEN MANUFA	CTURER AND USER	
	Annex J of IEC 60947-1 applies, as far as covered by clauses and of this standard, with the following additions		N/A
5.2.5	Relationship between the positions of the actuator of rotary switches and the associated contact element positions in the operating diagram (indication by the manufacturer)		N/A
5.2.6	Characteristics of the delay of time contact elements with adjustable delay of contactors relays (indication by manufacturer)		N/A
6.1.1 (Annex K)	Choice of connecting conductors for position switches with direct opening action		N/A
8.3.1	Test sequences made on one sample only (at manufacturer's request)		N/A
8.3.4.3	Conditional short-circuit current test:		N/A
	- adjustment of the test current if the prospective current is different from 1000 A (to be specified by the manufacturer)		N/A
	- power factor of the test circuit less than 0,5 (with manufacturer's consent		N/A



Annex F	CLASS II CONTROL CIRCUIT DEVICES INSULATED BY ENCAPSULATION REQUIREMENTS AND TESTS	
F.1	General	
	This annex specifies constructional requirements and tests for class II control circuit devices or parts of devices in which insulation of class II according to IEC 61140 is archived by encapsulation	N/A
	All non-encapsulated parts shall have clearances and creepage distances two times those specified in 7.1.3	N/A
F.5	Marking	
	Control devices according to this annex shall be marked with the following symbol	N/A
F.7	Instructional and functional requirements	
F.7.1	Choice of compound	
	The compound shall be chosen so that the encapsulated control devices comply with the tests defined in F.8.	N/A
F.7.2	Adhesion of the compound	
	The adhesion of the compound shall be sufficient to prevent the ingress of moisture between the compound and all encapsulated parts and to prevent movement of the encapsulated portion of cable if any.	N/A
	Compliance shall be verified by tests of F.8.2.5 and F.8.1.2.2.	N/A
F.7.3	Dielectric properties	
	Sub-clause 7.2.3 applies with the following changes:	N/A
	For the verification of the impulse withstand voltage, the test voltage Uimp shall be the next higher category of the maximum rated operational voltage in the first column of Table H.1 of IEC 60947-1 for stated overvoltage category	N/A
	For verification of the power frequency withstand voltage, the test voltage shall be the sum of the voltage stated in Table 12A of IEC 60947-1 plus 1000 V	N/A
F.8	Tests	
F.8.1	Kind of tests	
F.8.1.1	General	
	Sub clause 8.1.1 of IEC 60947-1 applies	N/A
F.8.1.2	Type test	
	The following sequence of 6 tests shall be applied to each of 3 samples in the specified order	N/A
F.8.1.2.1	Dielectric tests in new conditions	

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 37 of 65 page



age. 370	n os page		
	Sub clause 8.3.3.4 of IEC 60947-1 applies with the exception that the values of voltages shall be applied between the stripped joined ends of the cable or the shorted terminals and any point of the surface (or metallic foil on the surface) of the encapsulated device (see fig F.1)		N/A
	No breakdown of the insulation shall occur		N/A
F.1.2.2	Cable tests (if applicable)		
	Control circuit devices provided with integrally connected cables shall comply with the requirements of Annex G		N/A
F.8.1.2.3	Rapid change of temperature test		
	Test Na shall be performed in accordance with IEC 60068-2-14 with the following values:		
	Ta and Tb are the minimum and the maximum	Ta (°C):	N/A
	temperatures stated in f.2.3	T _b (°C):	
	Transition time t ₂ :	t ₂ = 2 to 3 min	N/A
	Number of cycles:	5	N/A
	Exposure time t ₁ :	t ₁ = 3 h	N/A
	After the test no visible damage shall be observed		N/A
F.8.1.2.4	Impact test		
	The test is performed as follow:	See Figure F.2	
	Thee impacts of 0,5 Joule shall applied near the centre of the largest surface or the longest axis (for cylindrical shape) of the encapsulated device		N/A
	The impacts are provided by dropping a steel ball of 0,25 kg from a height of 0,20 m		N/A
	The support is considered sufficiently rigid if its displacement under the impact energy is lower than 0,1 mm		N/A
	After the test no visible damage shall be observed		N/A
F.8.1.2.5	Damp heat, cyclic	I	
	Test Db shall be performed in accordance with IEC 60068-2-30 with the following values:		
	Upper temperature:	55 °C	N/A
	Number of cycles:	6	N/A
	Variant:	□ 1	N/A
		□ 2	
	After the test no visible damage shall be observed		
F.8.1.2.6	Dielectric test after stresses		
	Test of dielectric properties, dielectric withstand voltage (Uimp not indicated):		N/A
	rated insulation voltage (V) test voltage (V) for 5 sec:	Utest (V):	N/A

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 38 of 65 page

11	CONSULTING & TESTING	6	-4	-
	JER	ų		

~	gei 66 ei 1			
		Leakage current measurements at 1,1 Ui shall not	Leakage current (mA):	N/A
		exceed 2 mA:		



Annex G	ADDITIONAL REQUIREMENTS FOR CONTROL CIRCUIT DEVICES WITH INTEGRALLY CONNECTED CABLES	
G.1	General	
	This annex gives additional requirements applying to control circuit devices with integrally connected cables for electrical connection to other equipment and / or to the power source.	
	The cable integrally connected to such control devices is not considered replaceable by the user.	
	This annex states the constructional and performance requirements for the cable, the cable anchorage and the cable entrance seal	
G.7	Constructional and performance requirements	
G.7.1	Constructional requirements	
G.7.1.1	Cable material	
	The control device shall be provided with flexible cable of appropriate voltage, current and temperature rating and environmental condition	N/A
G.7.1.2	Cable anchorage	
	The cable anchorage shall be such that a force being applied to the cable is not transmitted to electrical connections integral to the device	N/A
	Movement of the cable intro or out of the control circuit device shall not cause damage to the connection or internal parts of the device	N/A
G.7.1.3	Cable entrance sealing means	
	A sealing means shall provided at the cable entrance to the control circuit device suitable for the degree of protection or internal parts of the device	N/A
G.7.2	Performance requirements	
	The cable and the cable entrance sealing means shall be capable of withstanding the tests given in G.8	N/A
G.8	Tests	
	The purpose of these tests is to ensure integrity of the cable anchorage during handling and installation. Once installed, the control circuit device and cable should be fixed relative to each other	N/A
G.8.2	Type test	
	The following sequence of four test shall be performed on a representative sample in the specified order	N/A
G.8.2.2	Pull-out test	
	The cable shall be subjected to a steady pull along the axis of the cable entry, applied to the insulating jacket of the cable for a duration of 1 min	N/A
	Sub clause 8.2.4.4 of IEC 60947-1 applies.	N/A

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 40 of 65 page



ige. 40	or os page		
	In cases when cables consist of more than one conductor the pulling force is determined by	Diameter cable (mm): Pull force (N):	N/A
	multiplying the pulling force for a single conductor by the number of conductors in the cable. The maximum pulling force shall not exceed 160 N		
G.8.2.3	Torque test		
	The cable shall be subjected to a torque of 0,1 Nm or limited to the value giving an angle of torque of 360°	Torque (Nm):	N/A
	The torque shall be applied clockwise and then counter-clockwise for 1 min, to the cable at a distance of 100 mm from the control circuit device entrance		N/A
G.8.2.4	Push test		
	The push force shall be applied along the axis of the cable as close as possible to the cable entrance		N/A
	The force is increased to 20 N. The force shall be applied for 1 min for each time and with 1 min pause between applications		N/A
	After the tests, no visible damage of the cable entrance sealing means and no displacement of the cable shall be observed		N/A
G.8.2.5	Bend test		
	The cable shall be loaded and bent in the following manner:		N/A
	a) suspend a 3 kg mass by attaching it to the cable,1 m from the cable entrance and with the axis of the cable entrance vertical		N/A
	b) tilt the control circuit device 90° to cause a 90° bend in the cable, maintaining that position for 1 min		N/A
	c) tilt the control device 90° in the opposite direction relative to vertical so as to cause an opposite 90° bend in the cable, maintaining the position for a duration of 1 min.		N/A
G.8.3	Results to be obtained		
	There shall be no damage to the cable, cable sealing means, cable entrance or the electrical connecting means of the control circuit device.		N/A
	This will be verified by visual examination and verification of compliance with the stated IP designation	See 7.1.11	N/A



Annex H	ADDITIONAL REQUIREMENTS FOR SEMICONDU ELEMENTS FOR CONTROL CIRCUIT DEVICES	CTOR SWITCHING	
H.3	Classification		
H.3.1	Semiconductor switching elements may be classified	as follows:	
	1) Utilization categories (see 4.4. and H.4.2)		N/A
	2) Electrical ratings based on utilization categories (see annex A)		N/A
H.5	Product information	·	
	The following information shall be given by the manufacturer:		
	Clause 5.1 applies with the following additions:		N/A
	Basic rated values and utilization		N/A
	a) Voltage drop (H.7.1.1):	U _d (mV):	N/A
	b) Minimum operational current:	I _m (A):	N/A
	c) Off-state current:	Ir (A):	N/A
	d) Making and breaking capacities:	AC / DC	N/A
	e) Conditional short-circuit current:	Normal 1000 A at Ue	N/A
	f) Electromagnetic compatibility, EMC:	environment A environment B	N/A
H.8	Tests		
H.8.1	Type test		
	Subclause 8.1.2 applies with the following additions:		N/A
H.8.2	Voltage drop (U₀)		
	The voltage drop is measured across the active output of the switching element in the ON state and carrying the current range of I_m and I_e at an ambient temperature of 23°C ± 5 °C and at rated frequency.		N/A
	The measurement is performed with the circuit in	U _e (V):	N/A
	figure H.2, with the switch S closed.	Im (A):	
	obtain the test current with the supply voltage	I _e (A):	
	Voltage drop at Im	U _d (mV):	N/A
	Voltage drop at Ie	U _d (mV):	N/A
	The measured voltage drop exceed not the specified value in H.7.1.1		N/A
H.8.3	Minimum operational current (I _m)		
	The test is performed with the switching element connected to a test circuit shown in fig H.2. With supply voltage (U _e), the switch open and the switching element in ON-state conduction, the resistive load R1 is adjusted to obtain the current I_m :	U _e (V): I _m (A):	N/A
	The measured value shall be according to H.7.1.2 :	Min. stated value: I _m (A): Measured: I _m (A):	N/A

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 42 of 65 page



H.8.4	OFF-state current (Ir)		
	With the circuit in Figure H.2, and the S switch closed, the load R2 is adjusted to obtain the rated operational current (I_e) when the highest supply voltage (U_e) is connected to the circuit. The switching element is then turned off and the OFF-state current is measured	U _e (V): I _e (A):	N/A
	The measured value shall be according to H.7.1.3:	Min. stated value: Ir(A): Measured: Ir(A):	N/A
H.8.5	Making and breaking capacities		
	Subclause 8.3.3.5 applies		N/A
8.3.3.5.2	Making and breaking capacities of switching element	s under normal conditions	
	contact element (figure / form):		
	contact polarity:		
	utilization category (AC/DC):		
	rated operational voltage Ue (V):		
	rated operational current le (A) or power (kW):		
Test No.1	- test voltage U/Ue = 1,1 (V):	L1: L2: L3:	N/A
	- power factor/time constant:	L1: L2: L3:	N/A
	- make operations: test current I/Ie (A):	L1: L2: L3:	N/A
	- break operations: test current I/Ie (A):	L1: L2: L3:	N/A
	 a.c. test: Inductor shunted by a resistor taking 3% of the total power consumed d.c. test: test current increase from zero to steady-state value within limits of figure 9 		N/A
	- on-time (ms):		N/A
	- operating cycles per minute:	6	N/A
	- number of operating cycles:	50	N/A
	- test voltage U/Ue = 1,0 (V):	L1: L2: L3:	N/A
	- power factor/time constant:	L1: L2: L3:	N/A

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 43 of 65 page



<u>90. 400</u>	- make operations: test current I/Ie (A)	L1:	N/A
		L2:	
		L3:	
	- break operations: test current I/Ie (A):	L1:	N/A
		L2:	
		L3:	
Test No. 2	- on-time (ms):		N/A
	- operating cycles per minute:	Rapidly	N/A
	- number of operating cycles:	10	N/A
Test No. 3	- on-time (ms):		N/A
	- operating cycles per minute:	60	N/A
	- number of operating cycles:	990	N/A
Test No. 4	- on-time (ms):		N/A
	- operating cycles per minute:		N/A
	- number of operating cycles:	5000	N/A
	Behaviour and condition during and after the test:		
	- no electrical or mechanical failures		N/A
	- no contact welding or prolonged arcing		N/A
	- no blowing of the fusible element in the earth circuit		N/A
	Dielectric verification:		
	dielectric test voltage (V) 2 xUe with a min.of 1000V:		N/A
8.3.3.5.3	Making and breaking capacities of switching elements	s under abnormal conditions:	
	contact element (figure / form):		
	contact polarity:		
	utilization category (AC/DC):		
	rated operational voltage Ue (V):		
	rated operational current le (A) or power (kW):		
	Conditions, make/break operations:		
	- test voltage U/Ue = 1,1 (V)	L1:	N/A
		L2:	
		L3:	
	- power factor/time constant:	L1:	N/A
		L2:	
		L3:	
	- make operations: test current I/Ie (A):	L1:	N/A
		LZ:	
	brook operations: test surrent I/Is (A)		N1/A
		L2:	IN/A
		L3:	

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 44 of 65 page



ge: 44	of 65 page		
	- a.c. test: Inductor shunted by a resistor taking 3% of the total power consumed		N/A
	- d.c. test: test current increase from zero to steady- state value within limits of figure 9		
	- on-time (ms):		N/A
	- operating cycles per minute:	6	N/A
	- number of operating cycles:	10	N/A
	Behaviour and condition during and after the test:		
	- no electrical or mechanical failures		N/A
	- no contact welding or prolonged arcing		N/A
	- no blowing of the fusible element in the earth circuit		N/A
	Dielectric verification:		
	dielectric test voltage (V) 2 xUe with min.of 1000V:		N/A
H.8.6	Performance under short-circuit conditions		
8.3.4	Performance under conditional short-circuit current		
	contact element (figure / form):		N/A
	contact polarity:		N/A
	Maximum cable length	2 m	N/A
	type of SCPD:		N/A
	ratings of SCPD (A / V):		N/A
	prospective current (min- 1 kA) (kA):		N/A
	test voltage (V) 1,1 x Ue:		N/A
	r.m.s. test current obtained (kA):		N/A
	power factor (0,5- 0,7) / T _{0,95} (ms):		N/A
	first CO operation by closing the separate making switch: test Ip / I²dt (kA / kA²s):	L1:	N/A
	time interval between test (min. 3 min):		N/A
	second CO operation by closing the separate making switch: test Ip / I²dt (kA / kA²s):	L1:	N/A
	time interval between test (min. 3 min):		N/A
	third CO operation by closing the separate making switch: test lp / l²dt (kA / kA²s)	L1:	N/A
8.3.4.4	Condition of the switching element after the test	<u> </u>	
	switching elements open by the normal actuating system		N/A
	Dielectric verification:		
	dielectric test voltage (V) 2 xUe with min.of 1000V:		N/A
H.8.7	Verification of electromagnetic compatibility		
H.8.7.1	General		
	Subclause 8.4.1 applies with the following addition:		N/A



.ge: .ee:			
	The tests shall be performed:		N/A
	with the switching element in the ON-state		
	with the switching element in the OFF-state		
H.8.7.2	Immunity		
H.8.7.2.4	Surges		
	Subclause 8.4.2.4 applies with the following addition:		N/A
	the switching element is powered during the test		N/A
	Five positive and five negative impulses shall be applied between each two points at intervals of not less than 5 s		N/A
H.8.7.3	Emission		
	The test shall be performed under worst case conditions according to CISPR 11 Group 1, Class A, and 7.3.3.2 of IEC 60947-1		N/A
	These limits are given for switching elements	NOTICE	N/A
	exclusively intended for use in industrial environment A. When they can be used in domestic environment B, the following notice shall be included in the instructions for use	This is a Class A product. In a domestic environment this product may cause radio interference in which case the user may be required to take adequate measures	



Annex J	SPECIAL REQUIREMENTS FOR INDICATOR LIGHTS AND INDICATING TOWERS	
J.3	Classification	
	Indicator lights may be classified by:	
	rated electrical power	N/A
	colour	N/A
	Fixing hole diameter	N/A
	Means of connection	N/A
	Nature of current and frequency	N/A
	Type of lamp socket	N/A
	Nature of light source (for example: filament lamp, LED).	N/A
J.4	Characteristics	
J.4.1	Rated operational voltage of an indicator light (V) :	N/A
J.4.2	Rated thermal power of an indicator light (W)	N/A
J.4.3	Rated values of the lamp:	N/A
J.5	Product information	
	a - manufacturer's name or trademark	N/A
	b - type designation or serial number	N/A
	c – the following markings shall appear on the indicator light	N/A
	1 rated voltage of indicator light	N/A
	2 rated voltage of the lamp	N/A
	3 rated power of the lamp or its type designation, or rated current for a LED	N/A
J.6	Normal service, mounting and transport conditions	
	There are no supplementary requirements	N/A
J.7	Constructional and performance requirements	
	Clause 7 applies with the following additions	N/A
J.7.1.12	Indicator lights with build-in transformers	
	The transformer shall have separate windings	N/A
	It is assumed that this condition is fulfilled if the indicator light passes the test described in 8.3.3.4.1	N/A
J.7.2.1.6	Limits of operation	
	The limit value of the supply voltage at the terminals of the indicator light shall be 1,1, times the rated operational voltage	N/A
	This requirement is verified only for indicator lights with built-in transformer according the test described in J.8.3.3.3	N/A
J.7.2.5.1	Short-circuit withstandability of build-in transformer	

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 47 of 65 page



	The transformer shall be able to withstand the short- circuit of its secondary winding.		N/A
	It is assumed that this condition is fulfilled if the indicator light passes the test described in 8.3.3.3.		N/A
J.8	Tests		
J.8.3	Tests for indicator lights and indicator towers		
	The tests are type tests. No additional test(routine test or special test) is described in this annex		N/A
	Each of the tests in J 8.3.3.3, -3.4, -4, and j.8.4 shall be made on new apparatus		N/A
J.8.3.3.3	Temperature-rise test		
	a) If the indicator light has the same rated thermal power (see J.4.2) regardless of mounting conditions, a single test is made in an insulated enclosure.		N/A
	 b) If the rated thermal power (see J.4.2) is dependent on the mounting conditions, two tests are made: - on a steel plate, and - in an insulated enclosure 		N/A
	c) Mounting on a steel plate		NI/A
	Five indicator lights fitted with green lenses are fixed in accordance with the following diagram on a steel plate 2 mm thick, painted black		N/A
	The plate is located vertically on a table and the indicator lights are supplied at their rated voltage :	Utest (V):	N/A
	The duration of the test shall be such that a steady- state temperature is reached		N/A
	d) Mounting in an insulating enclosure The test described in item c) is carried out again. With the lights into an enclosure of insulating material, such as Bakelite-coated paper 2 mm thick		N/A
	The plate is located vertically on a table and the indicator lights are supplied at their rated voltage :	Utest (V):	N/A
	The duration of the test shall be such that a steady- state temperature is reached		N/A
	Results obtained on the follow points:		
	- on the body of the indicator light (K):	measured (K): allowed (K):	N/A
	- on the terminals:	measured (K): allowed (K):	N/A
	- on the accessible part of the lens:	measured (K): allowed (K):	N/A
	f) For indicating towers, an arrangement of 5 units shall be mounting in vertical position. The shall be loaded maximum power of the lamp at the nominal voltage	Utest (V):	N/A

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 48 of 65 page



<u>ge: 48 01</u>	os page		
	The duration of the test shall be such that a steady- state temperature is reached		N/A
	- on the accessible part of the centre lens of the	measured (K):	N/A
		allowed (K):	
	None of the corresponding temperature rises exceed the limits of 7.2.2 of IEC60947-1		N/A
J.8.3.3.4	Dielectric tests		
	Clause 8.3.3.4 applies		N/A
J.8.3.3.4.3	Indicator lights with build-in transformers		
	Two additional dielectric tests shall be made, the duration of each being 1 min		N/A
	- between the primary and secondary windings of the transformer with the test voltage value specified in 8.3.3.4	Utest (V):	N/A
	- between the secondary windings of the transformer and the frame of the indicator light with a test voltage of 1000 V		N/A
J.8.3.4	Short-circuit test (on built-in transformer, if any)		
	The test are made under the following conditions:		
	- primary voltage: 1,1 x Ue	Utest (V):	N/A
	- ambient air temperature: 20 °C ± 5 °C :	Ambient (°C):	N/A
	- duration: 1 h		N/A
	The transformer shall be short-circuit by a conductor of negligible impedance		N/A
	After the test and after cooling to ambient, temperature, the transformer withstand the dielectric test defined in J.8.3.3.4.3		N/A
J.8.3.3.4.3	Indicator lights with build-in transformers		
	Two additional dielectric tests shall be made, the duration of each being 1 min		N/A
	- between the primary and secondary windings of the transformer with the test voltage value specified in 8.3.3.4	Utest (V):	N/A
	- between the secondary windings of the transformer and the frame of the indicator light with a test voltage of 1000 V		N/A
J.8.4	Shock and vibration		
J.8.4.1	General		
	Tests for shock and vibration shall be carried out for indicating towers only. Indicator lights are not considered to be tested.		N/A
J.8.4.2	Direct mounting	1	
J.8.4.2.1	General		
· ··—••			

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 49 of 65 page



ye. 490	i oo page		
	An indicating tower with five signalling units shall be mounted as stated by the manufacturer without extension poles and the upper three units powered at the rated voltage	Utest (V):	N/A
	The test shall be performed as follows		N/A
J.8.4.2.2	Shock		
	In accordance with IEC 60068-2-27 with the follow conditions		N/A
	Six shocks applied in each direction along three perpendicular axes (a total of 36 shocks):	- pulse shape: half-sine - peak acceleration: 15 g _n - duration of pulse: 11 ms	N/A
J.8.4.2.3	Vibration	·	
	In accordance with IEC 60068-2-6 with the following conditions, along three mutually perpendicular axes:	 frequency range: 10 to 55 Hz amplitude: 0,5 mm sweep cycle duration: 5 min duration at resonant frequency or at 55 Hz: 30 min in each of the 3 axes (90 min in total) 	N/A
J.8.4.3	Indirect support mounting		
	If the product literature includes other allowable mounting conditions (e.g. pole mounting), the manufacturer shall state the severity level for shock and vibration tests at which the requirements of J.8.4.3 are met		N/A
J.8.4.4	Results to be obtained	·	
	After the tests, no visible damage shall be observed and the signalling shall not be impaired		N/A
J.8.5	Degree of protection for indicating towers	·	
	If the manufacturer declares a degree of protection, the test shall be conducted according to Annex C of IEC 60947-1 with all removable parts equipped as in normal service.		N/A



Annex K	SPECIAL REQUIREMENTS FOR CONTROL SWIT	CHES WITH DIRECT	
K.1	General		
	All control switches with direct opening action shall also comply with the relevant requirements of the standard and, where applicable. To those given in Annexes F, G, H and/or J		N/A
K.3	Classification		
	There are two types of control switches with direct opening action:	☐ type 1 ☐ type 2	N/A
K4	Characteristics		
K.4.3.1.2	Rated insulation voltage (min. 250 V)	Ui (V):	N/A
K.4.3.2.1	Conventional free air thermal current (min. 2.5 A):	Ith (A):	N/A
K.4.4	Utilization categories for switching elements (AC-15 or DC-13):		N/A
K.5	Product information		
	Clause 5 is applies with the following additions		N/A
K.5.2	Marking		
K.5.2.7	Every contact element with direct action shall be marked on the outside by the symbol	→ IEC 60617-S00226 (2001-07)	N/A
K.5.2.8	Electrical separation for change-over contact element		N/A
	Change-over contact elements with four terminal shall be indelibly and legibly marked with the relevant form Zap or Zebu as state in Figure 4.		N/A
K.5.2	Additional product information		
K.5.4.1	Actuator travel and operation force		
	The manufacturer shall state the following		
	a) the minimum direct opening travel (mm):		N/A
	b) the minimum force to achieve direct opening action of all break contacts (N):		N/A
	c) the maximum travel including travel beyond the minimum travel position (mm)		N/A
	d) for limit switches only the maximum speed of actuation:		N/A
	e)for limit switches only the maximum frequency of actuation		N/A
	These statements shall appear in the marking or on the circuit diagram or other documents		N/A
K.5.4.2	Short-circuit protection		
	Type of short-circuit protective device shall be stated either as marking on the switch or in the installation instruction		N/A

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 51 of 65 page



K.0	Normal service, mounting and transport conditions	
	Clause 6 applies, with the following additions:	N/A
K.6.1.1	Ambient air temperature	
	Sub clause 6.1.1 of IEC 60947-1 applies, except for position switches with direct opening action, for which the upper and lower limits of temperature are respectively +70 °C and +25 °C, and the average temperature, measured over a period of 24 h, does not exceed +35 °C	N/A
K.7	Constructional and performance requirements	
	Clause 7 applies with following additions:	N/A
K.7.1.4.3.1	Robustness of the actuating system	
	The actuating system shall pass the test described in K.8.3.7	N/A
K.7.1.4.3.2	Directness of the opening action	
	The control switch with direct opening action shall pass the tests K.8.3.4, K.8.3.5 and K.8.3.7 without any deformation that would reduce the impulse voltage withstand across the contact gap.	N/A
K.7.1.4.5	Automatic opening of cable operated control switches	
	In case of failure of the cable or its anchorage automatic return to open position	N/A
K.7.1.4.6	Conditions for direct opening action	
	Parts of travel that separates the contacts, shall have no resilient member (springs) between the moving contacts and the point of the actuator to which the actuating force is applied	N/A
K.7.1.4.6.1	Contact elements types	
	Control switches with direct opening action may be provided with snap-on or dependent action contact elements	N/A
	Break-contact shall be electrically separated from each other and from the operating make-contact element	N/A
	If C or Za change-over contact elements, only 1 contact element shall be used, and in case of Zebu change-over, both may be used	N/A
K.7.1.5.3	Actuator travel indication	
	In order to facilitate the setting-up of the switch actuator in relation to the external operating means, the switch may include means for indicting the minimum travel	N/A
K8	Tests	
	In addition to clause 8, and Annex, the following applies	N/A
K.8.3.1	Test sequences	
	Clause 8.3.1 applies with the following additions:	N/A



	TEST SEQUENCE VII (Sample 7)	
	Mechanical operation of position switches with direct opening action	
K.8.3.5	Test no.1 - Mechanical operation of position switches at limits of temperature	
K.8.3.6	Test no.2 – Verification of direct opening action	
K.8.3.5	Mechanical operation of position switches at limits of temperature	
	The position switch shall be conditioned at 70°C for 8 hours	N/A
	After 8 hours the contact shall be loaded with the maximum rated operational current for 10 min (A) :	N/A
	The contact then be operated 10 times by the application of the force stated by the manufacturer (N)	N/A
	The test shall be repeated, the switch shall be conditioned at - 25 °C for 8 hours	N/A
	The contact then be operated 10 times by the application of the force stated by the manufacturer (N)	N/A
K8.3.6	Verification of direct opening action	
	Impulse voltage test over the open position of the contacts at 2500 V or for position switches for isolation in accordance with table 14 of IEC 60 947-1 or as declared Uimp by the manufacturer (V) :	N/A
	5 positive and 5 negative impulses are applied : Utest (V):	N/A
14 0 0 7		
K.8.3.7	Cleared break contents of the actuating system	N1/A
	F1 of 10 N	N/A
	Stated openings force F2 shall be applied to the actuator through the direct opening travel (N)	N/A
	After the test the actuating system and / or contacts shall remain functional	N/A
	Impulse voltage test in accordance with K.8.3.6	N/A
	Impulse voltage test over the open position of the contacts at 2500 V or for position switches for isolation in accordance with table 14 of IEC 60 947-1 or as declared Uimp by the manufacturer	N/A
	5 positive and 5 negative impulses are applied : Utest (V):	N/A
K.8.3.4	Performance under conditional short circuit current	
	Sub clause 8.3.4 applies with the following additions:	N/A
	Sub clause 8.3.4 applies with the following additions:	N/

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 53 of 65 page



age. 0001	US page		
K.8.3.4.2.1	Verification of the conditional short-circuit current		
	The test shall be made as stated in 8.3.4.2, except that the current is made by a direct opening contact element and not by the additional switching device and the test is made on the device by making the current three times by the same contact element in a single phase circuit.		N/A
	For type 2 control switches, the contact element shall be chosen at random		N/A
	Performance under conditional short-circuit current		
	contact element (figure / form):		N/A
	contact polarity:		N/A
	type of SCPD		N/A
	ratings of SCPD (A / V):		N/A
	prospective current (min- 1 kA) (kA)		N/A
	test voltage (V) U/Ue = 1,1 (V):	L1:	N/A
	r.m.s. test current obtained (kA)	L1:	N/A
	power factor (max. 0,7)		N/A
	Sample 4		N/A
	first C operation by closing the switch element Ip / I²dt (kA / kA²s):	L1: L1:	N/A
		L1:	
	time interval between test (min. 3 min):		N/A
	second C operation by closing the switch element Ip / I²dt (kA / kA²s)	L1: L1: L1:	N/A
	time interval between test (min. 3 min)		N/A
	third C operation by closing the switch element Ip / I²dt (kA / kA²s):	L1: L1: L1:	N/A
	Sample 9		N/A
	first C operation by closing the switch element lp / l²dt (kA / kA²s):	L1: L1: L1:	N/A
	time interval between test (min. 3 min):		N/A
	second C operation by closing the switch element	L1:	N/A
	Ip / I²dt (kA / kA²s):	L1: L1:	
	time interval between test (min. 3 min)		N/A
	third C operation by closing the switch element: Ip / I²dt (kA / kA²s)	L1: L1:	N/A
	Sample 10	LI.	N/A

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 54 of 65 page

11	CONSULTING & TESTING		-
	YCER	C7	

	first C operation by closing the switch element	L1:	N/A
	Ip / I²dt (kA / kA²s):	L1:	
		L1:	
	time interval between test (min. 3 min):		N/A
	second C operation by closing the switch element	L1:	N/A
	Ip / I²dt (kA / kA²s):	L1:	
		L1:	
	time interval between test (min. 3 min):		N/A
	third C operation by closing the switch element	L1:	N/A
	lp / l²dt (kA / kA²s):	L1:	
		L1:	
K.8.3.4.4.1	Operation ability after the test		
K.8.3.4.4.1	After each test, the opening contact element shall		N/A
	open by the application of the force stated		
	travel (see items a) and b) of K.5.4.1).		
	Impulse voltage test in accordance with K.8.3.6		
	Impulse voltage test over the open position of the contacts at 2500 V or for position switches for isolation in accordance with table 14 of IEC 60 947-1 or as declared Uimp by the manufacturer		N/A
	5 positive and 5 negative impulses are applied :	Utest (V):	N/A



Annex L	SPECIAL REQUIREMENTS FOR MECHANICALLY LINK ELEMENTS	ED CONTACT
L.1	General	
	This annex applies to mechanically linked auxiliary contact elements included in control circuit devices where actuating force is provided internally, such as contactor relays	N/A
	Linkage between the auxiliary and main contacts is not covered by this annex	N/A
L.5	Product information	
	Clause 5 applies with the following addition	N/A
L.5.2.7	Mechanically linked contact elements identification and ma	rking
	Mechanically linked contact elements shall be clearly identified:	N/A
	on the control circuit device itself; or in the manufacturers documentation or both	N/A
	The mechanical linkage shall be identified in circuit diagrams by a double parallel line connecting a filled circle on each of the mechanically linked contact symbols.	N/A
	If the devices containing some or all mechanically linked contacts are marked, the symbol shown shall be used	N/A
L.7	Constructional and performance requirements	
	Clause 7 applies with the following addition:	N/A
L.7.1.9	Requirements for mechanically linked contact elements	
	While any of the n Make contact element(s) is closed, none of the m Break contacts element(s) shall be closed	N/A
	While any of the m Break contact element(s) is closed, none of the n Make contacts element(s) shall be closed	N/A
L.8	Tests	
	Clause 8 applies with following addition:	N/A
L.8.4.	Special test for mechanically linked contact elements	
	This special test shall be carried out on a sample of (m+n) products where m is the number of break contacts elements and n is the number of make elements	N/A
	A different sample is used for each test	N/A
	The test shall be carried out on products in new and clean condition	N/A
	The test procedure shall be as follows:	N/A
	a) test of NC contact:	N/A

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 56 of 65 page



N/A
N/A



Annex M	TERMINAL MARKING, DISTINCTIVE NUMBER AND DISTINCTIVE LETTER FOR CONTROL CIRCUIT DEVICES	
M.1	General	
	This annex applies to control switches and contactor relays irrespective of their construction, having terminal marking.	N/A
M.2	Terminal marking rule	
M.2.1	General	
	Terminal marking in accordance with this annex is based, in principle, on a two-digit number.	N/A
M.2.2	Function digit	
	Sub clause L.3.2.1 of IEC 60947-1 applies.	N/A
M.2.3	Sequence digit	
	The tens digit is a continuous sequence number beginning with 1 (except for control switches designated 01 and contactor relays designated 01E), independent of the contact function	N/A
	Terminals belonging to the same contact are marked with the same sequence digit.	N/A
	For contactor relays having 10 contact elements, the sequence digit 0 is used instead of 10.	N/A
	The sequence digit may be omitted from the terminal marking only if additional information provided by the manufacturer or the user clearly gives such digit.	N/A
M.2.4	Numbering method	
	The contact terminals shall be numbered sequentially from left to right on the device; for devices with tiers of terminals, the numbering shall begin with the tier nearest to the mounting level.	N/A
M.3	Distinctive number distinctive letter	
M.3.1	General	
	The quantity and type of the contact elements of a control switch according to this annex are indicated by a distinctive number. Contacts of contactor relays are indicated by a distinctive number followed by a distinctive letter.	N/A
M.3.2	Distinctive number	
	The first digit of the distinctive number gives the quantity of make contact elements and the	N/A
	second digit the quantity of break contact elements. The third digit, if any, shall give the	
	quantity of change-over contact elements in control switches.	
M.3.3	Distinctive letter	

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 58 of 65 page



	, er ee bage		
	The distinctive letter indicates the location of the contact elements of a contactor relay in relation to each other and their terminal marking.		N/A
M.4	Terminal numbering sequence		
	For control switches having the same distinctive number, the terminal marking is specified in Table M.1.		N/A
	The position of the contact elements of the control switch need not correspond to that shown on diagrams of Table M.1.		N/A
M.5	Contactor relays designated by the distinctive letter E		
	For contactor relays having the same distinctive number and the distinctive letter E, independently of their construction, the sequence of the contact elements within the device is specified in accordance with the diagrams of Table M.2.		N/A
M.6	Contactor relays designated by the distinctive letter X	, Y or Z	
M.6.1	Contactor relays designated by the distinctive letter Z		
	If the location of the contact elements within the device (but not the terminal marking) differs from the provisions of Clause M.5, the device shall be designated by the distinctive letter Z instead of the distinctive letter E.		N/A
M.6.2	Contactor relays designated by the distinctive letter X		
	If the location of the contact elements within the device and the terminal marking both differ from the requirements of Clause M.5, the device shall be designated by the distinctive letter X instead of the distinctive letter E.		N/A
	The device shall comply with the requirements of Clauses M.2 and M.3.		N/A
M.6.3	Contactor relays designated by the distinctive letter Y		
	Devices consisting of combinations of contact elements and terminal marking in accordance with Table M.3 shall be designated by the distinctive letter Y instead of the distinctive letter E.		N/A



Annex N	Procedure to determine reliability data for electromechanical devices in control circuits used in functional safety applications	
N.3	Method based on durability test results	
N.3.1	General method	
	K.3.1 of IEC 60947-1:2007/AMD2:2014 applies.	N/A
N.3.2	Test requirements	
N.3.2.1	General	
	The test environment shall be in accordance with Clause 6.	N/A
	Every test shall be performed under the general conditions stated in 8.3.2.1 and at a rate equal or higher at the discretion of the manufacturer. The moving parts of the device shall reach their maximum operating positions in both directions, as recommended by the manufacturer. Reliability data to be published are described in Clause N.4.	N/A
N.3.2.2	Mechanical durability	
	The mechanical durability of a control circuit device is defined as the number of no-load operating cycles. For the no-make current or no-break current utilization the mechanical durability is applicable.	N/A
	During the test, periodically the contacts shall be checked at any voltage and current, selected by the manufacturer, and there shall be no failure.	N/A
N.3.2.3	Electrical durability	
	The electrical durability of a control circuit device is	N/A
	Electrical durability shall be determined in accordance with C.3.2 using utilization category AC-15 and / or DC-13 unless otherwise stated by the manufacturer.	N/A
N.3.3	Number of samples	
	K.3.3 of IEC 60947-1 applies with the following addition:	N/A
	The selection of samples to be tested for a series of devices with same fundamental design and without significant difference in construction shall be based on engineering judgment.	N/A
N.3.4	Characterization of a failure mode	
	K.3.4 of IEC 60947-1 applies	N/A
N.3.5	Weibull modelling	
	K.3.5 of IEC 60947-1 applies	N/A
N.3.6	Useful life and upper limit of failure rate	
	K.3.6 of IEC 60947-1 applies	
N.3.7	Reliability data	
	K.3.7 of IEC 60947-1 applies	N/A
N.4	Data information	

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 60 of 65 page

YGER	17	CONSULTING & TESTING	CT
------	----	----------------------	----

a	ge. 0001	oo page	
		K.4 of IEC 60947-1 applies	N/A
	N.5	Example	
		K.5 of IEC 60947-1 applies	N/A

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 61 of 65 page



TABLE 1: temperature rise				Р
Temperature rise dT of Part :	Phase	dT(K)	Requi	red dT(K)
Auxiliary contact	-	-		-
Line	1	44		60
Load	1	42.2		60
Parts intended to be touched but not hand-held	1	23.5		40
Ambient temperature		20°C		

TABLE: Heating test, resistance method								
	Test voltage (V):							—
Ambient, t ₁ (°C):								
	Ambient, t ₂ (°C):							
Temperatu	ire rise of winding	R ₁ (Ω)	R ₂ (Ω)		ΔΤ (Κ)	Max. dT (K)	Ins	ulation
Supplemen	tary information:							

TABLE: Dielectric Strength		
Test voltage applied between:	Test potential applied (V)	Breakdown / flashover (Yes/No)
Supplementary information:		

TABLE: Clearance And Creepage Distance Measurements								
clearance cl and creepage distance dcr at/of:		Up (V)	U r.m.s. (V)	Required cl (mm)	cl (mm)	required dcr (mm)	dcr (mm)	



Supplementary information:

TABLE: Distance Through Insulation Measurements					
Distance through insulation di at/of:	U r.m.s. (V)	Test voltage (V)	Required di (mm)	di (mm)	
Supplementary information:			·		



TABLE: Needle- flame test (NFT)							
10./	Manufacturer/ trademark	Duration of application of test flame (ta); (s)	Ignition of specified layer Yes/No	Duration of burning (tb) (s)	Verdict		
ry inform	nation:						
r	ABLE:	ABLE: Needle- flame test (N lo./ Manufacturer/ trademark y information:	ABLE: Needle- flame test (NFT) Io./ Manufacturer/ trademark Duration of application of test flame (ta); (s) y information:	ABLE: Needle- flame test (NFT) Io./ Manufacturer/ trademark Duration of application of test flame (ta); (s) Ignition of specified layer Yes/No visition Visition Visition visition Visiti	ABLE: Needle- flame test (NFT) Io./ Manufacturer/ trademark Duration of application of test flame (ta); (s) Ignition of specified layer Yes/No Duration of burning (tb) (s) Image: State of the state		

NFT not relevant (or applicable) for Parts of material classified as V-0 or V-1 NFT not relevant (or applicable) for Base material of PCBs classified as V-0 or if relevant VTM-0

TABLE: Resistance to heat and fire - Glow wire tests								
Object/ Part No./ Material	Manufacturer / trademark	Glow wire test (GWT); (°C)						
		550	650		750		050	Verdict
			te	ti	te	ti	850	
Object/ Part No./	Manufacturer	Glow-wire flammability index (GWFI), °C				GW ignition temp. (GWIT), °C		Verdict
Material	trademark	550	650	750	850	675	775	
The test specimen passed the glow wire test (GWT) with no ignition $[(te - ti) \le 2s]$ (Yes/No):								
If no, then surrounding parts passed the needle-flame test of annex E (Yes/No)								
The test specimen passed the test by virtue of most of the flaming material being withdrawn with the glow-wire (Yes/No)?:								
Ignition of the specified layer placed underneath the test specimen (Yes/No):								
Supplementary information: 550 °C GWT not relevant (or applicable) to parts of material classified at least HB40 or if relevant HBF								

The GWIT pre-selection option, the 850 °C GWFI pre-selection option, and the 850 °C GWT are not relevant (or applicable) for attended appliances.

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 64 of 65 page



List of test equipment used:

A completed list of used test equipment shall be provided in the Test Reports when a Manufacturer Testing Laboratory according to CTF stage 1 or CTF stage 2 procedure has been used. Note: This page may be removed when CTF stage 1 or CTF stage 2 are not used. See also clause 4.8 in OD 2020 for more details.

Clause	Measurement / testing	Testing / measuring equipment / material used, (Equipment ID)	Range used	Last Calibration date	Calibration due date

 Report. No.: TCT-TR01-221125-4

 Date:
 2022-11-25

 Page:
 65 of 65 page



Statement of Measurement Uncertainty

The Test Report shall include a statement concerning the uncertainty of the measurement systems used for the tests conducted when it is required by the standard, client or other authorities. In such cases, the table below is to be used for reporting U of M.

This page may be removed from the final Test Report when not required. See also clause 4.8 in OD 2020 for more details.

Clause #	Parameter/ Measurement / test method	Requirement % or k	Calculated U of M*

*Note: Calculations leading to the reported value are on file with the NCB